



Forsyth County Procurement

Greg Bridges, Procurement Agent III

December 1, 2021

ADDENDUM #2

RFP No. 21-188-5211

For: Lanierland Park Phase 2 Playground Design and Installation

This addendum supersedes and supplements all portions of the bidding documents and becomes part of the contract documents for the above-referenced project.

Where any item called for in the specifications or indicated on the drawings is supplemented hereby, the original requirements shall remain in effect.

Where any original item is amended, voided or superseded hereby, the provision of such item not so specifically amended, voided or superseded shall remain in effect.

Clarification on Bidder Questions:

1. **Q: Are there fencing and curb specs?** (19. The Contractor shall be responsible for the playground design, product, and installation, including final grading, **site curbing**, subsurface drainage, erection of play units, **fencing**, surfacing and ADA compliance factors.)

A: There is no fencing associated with the playground. The entire perimeter of the playground is bound by concrete pavement with an 18" turndown edge that the site contractor is providing. See below. The playground contractor would just need to pour to that turndown edge along the perimeter. Once a playground contractor is selected, it will need to be determined if they want the site contractor to provide that 1/2" radius on the nose of the pavement as shown. Not sure if that is too big of a radius for poured in place.

Concrete Turndown at Playground Area:

