



May 26, 2022

**ADDENDUM #3**

**RFQ 22-41-1514**

**Fowler WRF Return Flow to Lake Lanier  
Engineering and Design Services  
American Rescue Plan Act-State Fiscal Recovery Fund  
Water and Sewer Infrastructure  
Grant GA-000846**

**For:** Request for Qualifications for engineering and design services of the Fowler WRF Return Flow to Lake Lanier project.

This addendum supersedes and supplements all portions of the RFQ documents and becomes part of the solicitation documents for the above-referenced project.

Where any item called for in the scope of work is supplemented hereby, the original requirements shall remain in effect.

Where any original item is amended, voided, or superseded hereby, the provision of such item not so specifically amended, voided, or superseded shall remain in effect.

1. (As follow up to Offeror's Conference per request) - Confirm that separate third-party contracts will be used by the County for survey, SUE and geotechnical services and that no survey, SUE, or geotechnical scope will be included for the offering team.

**Answer: Existing owner procured annual contracts will be used by the County for Survey, SUE and Geotechnical Services. The Consultant/Designer will be able to request additional survey, SUE and geotechnical information that may be required for the design.**

2. Section 3.1 states "greater than 36-inch temperature diffusion" as an area of necessary experience for the offering team. Would the County consider revising this to "36-inch and greater" for the diffusion system to include the 36-inch size?

**Answer: Section 3.1-Introduction, first paragraph, second sentence, is revised to read as follows: "Consultants interested in this project should be experienced in large diameter water pipelines (36 inches and larger), vertical turbine pump stations (high pressure or long-distance pumping with a capacity greater than 15 MGD) and wastewater effluent diffuser systems (equal or greater than 36" for temperature diffusion)."**

3. With the utilization of ARPA funds, will the offering team need to meet a certain MBE/DBE percentage threshold for their services (building on requirements stated in Section 4.8 of the RFQ)?

**Answer: The ARPA-SFRF Water & Sewer Infrastructure Grant does not have any DBE requirements.**

**End of Addendum #3**