



Forsyth County Procurement

Greg Bridges, NIGP-CPP, Procurement Agent III

March 9, 2023

ADDENDUM #1

BID No. 23-010-3320

For: Antioch Water Treatment Plant Coatings and Rehab Phase 1

This addendum supersedes and supplements all portions of the bidding documents and becomes part of the contract documents for the above-referenced project.

Where any item called for in the specifications or indicated on the drawings is supplemented hereby, the original requirements shall remain in effect.

Where any original item is amended, voided or superseded hereby, the provision of such item not so specifically amended, voided or superseded shall remain in effect.

Clarification on Bidder Questions:

- 1. Q: Regarding the Owner's Protective Liability Insurance, is this in lieu of being named as an additional insured on the General Liability Policy or are both required?**
A: *Both are required.*
- 2. Q: If Installation Floater coverage is included in the Builder's Risk, which perils need to be insured against?**
A: *The Perils required are outlined in Item F.*
- 3. Q: Are we required to be insured against wind and flood?**
A: *It is not required unless identified in the Insurance requirements.*
- 4. Q: Are these Sherwin-Williams Company High Performance acceptable as a pre-approved Coating solution?**
Spot Coat – Macropoxy 920 Epoxy, B58T101
1st Coat – Macropoxy 646 FCE, B58-610 series
2nd Coat – Acrolon 218 HS, B65-600 series

A: Due to the fact that all process piping at the plant currently has coatings from a listed manufacturer and more specifically, the pipe being coated as a part of this project has previously been coated with a listed manufacturer, the Sherwin-Williams Company High Performance coatings are not being pre-approved for this particular project.

Note that we acknowledge that the Sherwin Williams Company High Performance products are currently accepted on a separate County project that involves newly installed process piping.