



Forsyth County Procurement

Greg Bridges, NIGP-CPP, Procurement Agent III

June 21, 2022

ADDENDUM #1

BID No. 22-68-3320

For: Champions Run Manhole Rehabilitation

This addendum supersedes and supplements all portions of the bidding documents and becomes part of the contract documents for the above-referenced project.

Where any item called for in the specifications or indicated on the drawings is supplemented hereby, the original requirements shall remain in effect.

Where any original item is amended, voided or superseded hereby, the provision of such item not so specifically amended, voided or superseded shall remain in effect.

Clarification on Bidder Questions and Submittals:

- 1. Q: Will Forsyth County approve Quadex/Vortex GeoKrete geopolymer manhole linings as an acceptable product in lieu of the specified cementitious with epoxy topcoat lining?**
A: No. The information provided does not sufficiently establish equivalency based on the requirements of the bid specifications.
- 2. Q: Would you consider Quadex AluminaLiner an acceptable Calcium Aluminate coating product equal to the base coat for the manhole rehabilitation portion of this project?**
A: Yes, however, the bidder must demonstrate meeting product requirements (Part 2 of bid specifications) before final approval.
- 3. Q: Would you consider Quadex Structure Guard as an acceptable Epoxy Liner Protective Coating Material equal to the topcoat for the manhole rehabilitation portion of this project?**
A: Yes, however, the bidder must demonstrate meeting product requirements (Part 2 of bid specifications) before final approval.

4. **Q: Would you consider Quadex GeoKrete as a “stand alone” single application geopolymer lining system equal to the base coat/epoxy topcoat for the manhole rehabilitation portion of this project?**

A: *No. The information provided does not sufficiently establish equivalency based on the requirements of the bid specifications.*