



Forsyth County Procurement

Donna H. Kukarola, CPPO, CPPB, Director

March 4, 2020

ADDENDUM #C

Bid 20-07-2210

For: Providing all labor, equipment and materials for the construction of an outdoor firing range for the Forsyth County Sheriff's Office. Range to be located at 9480 Old Federal Road.

This addendum supersedes and supplements all portions of the bidding documents and becomes part of the contract documents for the above-referenced project.

Where any item called for in the specifications or indicated on the drawings is supplemented hereby, the original requirements shall remain in effect.

Where any original item is amended, voided or superseded hereby, the provision of such item not so specifically amended, voided or superseded shall remain in effect.

Questions Received (response in *italics*)

1. Regarding the structural steel exposed to weather needing to be galvanized, does that also apply to pre-engineered metal structures? *Reference specification section 05 5000 for Miscellaneous Metals and specification section 13 3419 Metal Building Systems addressing galvanized members.*
2. We use as a manufacturer, A&S Building Systems. Would we be able to get them added to the acceptable manufacturers list? *As long as they comply with drawings and specifications.*
3. Can we get more detail on the requirements for the HESCO Barriers? Length, width(thickness) of the barriers? *HESCO barriers shall be a minimum 8' above grade (stacking may be required) with a total combined length of 580 linear feet. The general contractor can assume the Mil 1.9 product is used for this project*
4. Addendum B, Part 2, #2 states that the evaluation and testing of soils is to be by the GC. Is this correct, since the grading is not part of the scope of work for the GC? *Correct as required by the Owner.*
5. Addendum B, Part 2, #12-I do not see anything shown for the sewer system, it sounds like it will be a septic tank only. Can info be provided for this? Tank size, location, details? *The septic holding tank shall be a 500 gallon above ground septic holding tank placed in the location as shown on sheet C-4A. Holding tank shall be a low profile tank such as the Norwesco 44863, or approved equal*
6. Does the rifle range get AstroTurf similar to the pistol range? The details show it getting grass. Please clarify. There are also no landscape or grassing drawings, what is to be used at all disturbed areas? *The rifle range does not receive AstroTurf. The grassing requirements are shown in the specifications (Section 02930 – Grassing).*

END OF ADDENDUM NO C