



Forsyth County Procurement

Kimber Carder, Procurement Agent II

ADDENDUM #1

Bid Number: 22-78-3150	Title: Bridge Beam Painting
	Date: May 17, 2022
Issuing Officer: Kimber Carder	Bid Initially Solicited: July 14, 2022
Email Address: kncarder@forsythco.com	Telephone: 770-888-8872

This addendum supersedes and supplements all portions of the bidding documents and becomes part of the contract documents for the above-referenced project. Where any item called for in the specifications or indicated on the drawings is supplemented hereby, the original requirements shall remain in effect. Where any original item is amended, voided, or superseded hereby, the provision of such item not so specifically amended, voided or superseded shall remain in effect.

#	Questions	Referenced Bid Section	Answers
1.	Will the new paint match the existing paint? If so, do you know the style or SKU?	Bid Schedule	Paint will be in accordance with GDOT specifications, Section 535 – Painting Structures, using System VII paints as noted in the bid documents. Contractors MUST be GDOT pre-qualified to perform this type of work.