



Forsyth County Procurement
Hanna Milford, Procurement Agent II

March 30, 2020

ADDENDUM #1
Bid No. 20-47-2410

For: Providing all materials, equipment, and labor to provide Key Hose for the Forsyth County Fire Department

This addendum supersedes and supplements all portions of the bidding documents and becomes part of the contract documents for the above-referenced project.

Where any item called for in the specifications or indicated on the drawings is supplemented hereby, the original requirements shall remain in effect.

Where any original item is amended, voided or superseded hereby, the provision of such item not so specifically amended, voided or superseded shall remain in effect.

Questions/Revisions

1. Line item 15 is calling for:
100' x 5" Pro-Flow hose with swiveling Kochek Storz coupling Color: Red
Key hose no longer uses Kochek, and instead uses Action Couplings.. is this acceptable, or does the Fire Dept have to have Kochek?

Answer: If Kochek is not available then Action is OK as long as they swivel.

Sincerely,

Hanna Milford
Procurement Agent II