



**Forsyth County Procurement**  
**Stephanie Holbrook, Procurement Agent II**

DATE: September 27, 2021

**ADDENDUM #1**  
**BID NO. 21-126-1630**

For: To provide all materials, equipment, and labor for the Upgrade to existing Kantech Door Card Access for the Administration Building, 110 E Main Street, Cumming, GA 30040.

This addendum supersedes and supplements all portions of the bidding documents and becomes part of the contract documents for the above-referenced project.

Where any item called for in the specifications or indicated on the drawings is supplemented hereby, the original requirements shall remain in effect.

Where any original item is amended, voided or superseded hereby, the provision of such item not so specifically amended, voided or superseded shall remain in effect.

Questions/Clarifications:

- 1) Forsyth County is requesting that the existing Kantech KT-200 be uninstalled by the awarded supplier.
- 2) The Forsyth County Public Facilities Department will be responsible for the disposal of removed KT-200 panels.
- 3) The 1<sup>st</sup> floor will have all upgraded KT-400 relocated/installed in Room 153.
- 4) The 2<sup>nd</sup> floor will have all upgraded KT-400 relocated/installed in Room 237.
- 5) There are a total of 21 KT-200 panels that will need to be replaced with new KT-400 panels.
- 6) The awarded supplier will be responsible for all new wiring and new equipment needed for this upgrade and relocating of the KT-400 panels.
- 7) Kantech requires Dealer/Installers certification for the EntraPass Corporation Edition software and the EntraPass Global Edition software.
- 8) Background checks are required by the Forsyth County Sheriff's Office. The cost is \$20.00 per person.

- 9) The awarded supplier must schedule the installation with Public Facilities, Matt Roper, 404-615-2843.
- 10) Forsyth County will use the existing RS45 system to link the controllers with RS45 from the main/1<sup>st</sup> floor controller that is fed from the switch port.
- 11) This is a Turnkey completely operational project.
- 12) The extended due date will be requested by 11:00am Wednesday, October 6<sup>th</sup>, 2021.

Labor cost for removal of 21 existing KT-200 controllers/wiring: \$ \_\_\_\_\_

New KT-400 controller/wiring material cost: \$ \_\_\_\_\_

How many KT-400s will be needed to support this request? \_\_\_\_\_

Labor cost for installation of new KT-400 controller/wiring needed: \$ \_\_\_\_\_

Estimated lead time for the new controllers, delivery, and installation: \_\_\_\_\_

TOTAL QUOTE COST: \$ \_\_\_\_\_

Warranty of work and materials: \_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**The due date will be extended to 11:00am Wednesday, October 6th, 2021.**

Sincerely,


Stephanie Holbrook

Procurement Agent II

Forsyth County  
 Administration Building  
 110 E. Main Street  
 Cumming, GA 30040

**1-51**  
**1**  
**1-51**

DATE: 01/22/2014  
 PROJECT: FORSYTH COUNTY ADMINISTRATION BUILDING  
 DRAWING NO: 1-51  
 SHEET NO: 1-51  
 SCALE: AS SHOWN  
 PROJECT MANAGER: [Blank]  
 DESIGNER: [Blank]  
 CHECKER: [Blank]  
 DATE: [Blank]  
 DRAWN BY: [Blank]



**1**  
**1-51**  
**1-51**

First Floor -  
 Wall Finish  
 Plan

WB  
 INTERIORS

