



Forsyth County Procurement
Hanna Milford, Procurement Agent II

March 31, 2020

ADDENDUM #2
Bid No. 20-47-2410

For: Providing all materials, equipment, and labor to provide Key Hose for the Forsyth County Fire Department

This addendum supersedes and supplements all portions of the bidding documents and becomes part of the contract documents for the above-referenced project.

Where any item called for in the specifications or indicated on the drawings is supplemented hereby, the original requirements shall remain in effect.

Where any original item is amended, voided or superseded hereby, the provision of such item not so specifically amended, voided or superseded shall remain in effect.

Questions/Revisions

Is it possible for you to tell me why Key Hose is the spec for this order, if other companies have comparable products?

Answer: Key Hose is FCFD's standard for hose and has been for many years. At this time, FCFD does not want to deviate from its standard

Sincerely,

Hanna Milford
Procurement Agent II