



## Forsyth County Procurement Department

---

November 1, 2021

### **ADDENDUM #2 BID NO. 21-159-3340**

For: ***To provide as needed maintenance, repairs, inspections and washouts for Forsyth County Water Towers for the calendar year 2022.***

This addendum supersedes and supplements all portions of the bidding documents and becomes part of the contract documents for the above-referenced project.

Where any item called for in the specifications or indicated on the drawings is supplemented hereby, the original requirements shall remain in effect.

Where any original item is amended, voided or superseded hereby, the provision of such item not so specifically amended, voided or superseded shall remain in effect.

Questions received and responses (*in italics*) thereto:

1. Can commercial divers be used to complete interior cleaning (washout) & inspection services?  
***Answer: The tanks are to be drained prior to the washout.***
2. Can sediments removed during the washout be disposed of onsite?  
***Answer: Yes***

Larry Holtzclaw  
Contract Administrator