



Forsyth County Procurement

Greg Bridges, NIGP-CPP, Procurement Agent III

December 21, 2022

ADDENDUM #1

RFP No. 22-133-5211

For: Coal Mountain Park Playground Design and Installation

This addendum supersedes and supplements all portions of the bidding documents and becomes part of the contract documents for the above-referenced project.

Where any item called for in the specifications or indicated on the drawings is supplemented hereby, the original requirements shall remain in effect.

Where any original item is amended, voided or superseded hereby, the provision of such item not so specifically amended, voided or superseded shall remain in effect.

Clarification on Bidder Questions:

- 1. Q: Please explain the 6' curb you will be requiring around the playground?**
A: *The County will not require a 6-inch (not 6 foot) concrete curb as stated in the Requirements.*
- 2. Q: Please elaborate on the type of drainage you will be requiring: weep holes, French drains, etc.?**
A: *The drainage should meet the bonded rubber surface manufacturers requirements.*
- 3. Q: Do you have the measurements inside the fence?**
A: *56ft x 75ft.*