



## Forsyth County Procurement

Donna Kukarola, CPPO, CPPB, Procurement Director

September 10, 2018

### ADDENDUM #3

### Bid 18-117-1500

For: **Providing all equipment, materials and labor to renovate various suites within the Forsyth County Administration Building.**

This addendum supersedes and supplements all portions of the bidding documents and becomes part of the contract documents for the above-referenced project.

Where any item called for in the specifications or indicated on the drawings is supplemented hereby, the original requirements shall remain in effect.

Where any original item is amended, voided or superseded hereby, the provision of such item not so specifically amended, voided or superseded shall remain in effect.

#### **Response to questions received (*response in italics*):**

1. Note one on detail 1 on A102 specifies the door infills at office 104 and large conference room to be type B.2 walls. After reviewing the life safety plan on A003, these walls are one hour fire rated partitions. Please confirm the new infills mentioned above are to be wall type A.3

*The infills as referenced are to be one-hour fire rated type A.3.*

2. Note 9.1 on E100 calls for the installation of a 2" and 1" conduit from the telephone backboard to exterior of the rear of the building. Please confirm this scope is not to be included in this bid. *Those conduits are not necessary for this scope of work.*

No further questions will be accepted.

End of Addendum #3