



Forsyth County Procurement Department

November 26, 2018

ADDENDUM #2 BID NO. 18-168-1620

For: ***Alarm System Monitoring, Inspections, Maintenance and Repairs
for various Forsyth County Building Locations for the calendar year
2019.***

This addendum supersedes and supplements all portions of the bidding documents and becomes part of the contract documents for the above-referenced project.

Where any item called for in the specifications or indicated on the drawings is supplemented hereby, the original requirements shall remain in effect.

Where any original item is amended, voided or superseded hereby, the provision of such item not so specifically amended, voided or superseded shall remain in effect.

Questions received and responses ***(in italics)*** thereto:

1. Bid Specifications (Note): All systems are to be scheduled for a daily timer test. Are you asking for an open & close report each day from our Central Station?
Answer: A "Timer Test" is only ensuring that the system is communicating properly.

Questions will be accepted until Noon on Thursday, November 29, 2018.

Larry Holtzclaw
Contract Administrator