



Forsyth County Procurement

Greg Bridges, NIGP-CPP, Procurement Agent III

June 29, 2022

ADDENDUM #2

BID No. 22-68-3320

For: Champions Run Manhole Rehabilitation

This addendum supersedes and supplements all portions of the bidding documents and becomes part of the contract documents for the above-referenced project.

Where any item called for in the specifications or indicated on the drawings is supplemented hereby, the original requirements shall remain in effect.

Where any original item is amended, voided or superseded hereby, the provision of such item not so specifically amended, voided or superseded shall remain in effect.

Clarification on Bidder Questions and Submittals:

- 1. Q: Will Forsyth County consider SpectraShield as a single system in place of a cementitious base coat and epoxy top-coat?**
A: No. The information provided does not sufficiently establish equivalency based on the requirements of the bid specifications.
- 2. Q: If not considered for a single system, will Forsyth County consider SpectraShield an acceptable top-coat over a cementitious base coat?**
A: No. The information provided does not sufficiently establish equivalency based on the requirements of the bid specifications.
- 3. Q: Will Forsyth County consider Strong Seal MS-2C as an approved calcium aluminate base coat?**
A: Yes, however, the bidder must demonstrate meeting product requirements (Part 2 of bid specifications) before final approval.