



Forsyth County Procurement

Kimber Carder, Procurement Agent II

DATE 6/14/22

ADDENDUM # 4

| | |
|---|--|
| Bid Number: 22-57-1620 | Title: Shady Grove Bathhouse Roof Replacement |
| | Date: 6/14/22 |
| Issuing Officer: Kimber Carder | Bid Initially Solicited: 5/20/22 |
| Email Address: kncarder@forsythco.com | Telephone: 770-888-8872 |

This addendum supersedes and supplements all portions of the bidding documents and becomes part of the contract documents for the above-referenced project. Where any item called for in the specifications or indicated on the drawings is supplemented hereby, the original requirements shall remain in effect. Where any original item is amended, voided or superseded hereby, the provision of such item not so specifically amended, voided or superseded shall remain in effect.

Clarifications:

On addendum 3, a couple of the answers given were incorrect. Please see below revisions for questions 2 and 4.

| # | Questions | Answers |
|----|---|---|
| 2. | Regarding the outbuildings, will we be rebuilding the cornice (soffit/fascia), if so what material? | No, you will not be rebuilding the cornice. |
| 4. | Regarding the flat roofs on the bathrooms, is there any insulation required? | Yes, 2 layers of staggered insulation. |