



## Forsyth County Procurement

Greg Bridges, NIGP-CPP, Procurement Agent III

August 2, 2022

### ADDENDUM #3

### RFQ No. 22-076-3320

**For: Geotech Services for Church Rd. and Martin Rd. Gravity Sewer**

This addendum supersedes and supplements all portions of the bidding documents and becomes part of the contract documents for the above-referenced project.

Where any item called for in the specifications or indicated on the drawings is supplemented hereby, the original requirements shall remain in effect.

Where any original item is amended, voided or superseded hereby, the provision of such item not so specifically amended, voided or superseded shall remain in effect.

#### Clarification on Bidder Questions:

1. **Q: The sample Standard Terms and Conditions included in the RFQ appear more appropriate for materials purchasing than procurement of professional services. Can the successful firm expect contract language similar to that used in the Geotechnical Services As Needed contract?**

**A: *The Standard Terms and Conditions in the RFQ are for all Forsyth County Solicitations.***

2. **Q: The RFQ requires that if rock is encountered above the requested depths of the borings that the rock be cored to the requested boring depth. That practice is not typical for sewer line explorations as the additional data gathered does not justify the significant additional expense. Can we exclude rock coring?**

**A: *This is RFQ. No pricing is requested. The boring log form will indicate which boring needs to be core and to what depth. (see section III. Geotechnical Services, par. E.)***

3. **Q: The RFQ requires the rock core size be NWM if coring is required. NWM is not a standard core barrel used by drillers in this market. Will NQ size cores be sufficient?**

**A: *2) NQ is acceptable.***