

Forsyth County Procurement

Greg Bridges, Procurement Agent III

November 23, 2021

ADDENDUM #2 BID No. 21-177-3340

For: Liquid Oxygen Tank Rental and Liquid Oxygen and Liquid Nitrogen Supply

This addendum supersedes and supplements all portions of the bidding documents and becomes part of the contract documents for the above-referenced project.

Where any item called for in the specifications or indicated on the drawings is supplemented hereby, the original requirements shall remain in effect.

Where any original item is amended, voided or superseded hereby, the provision of such item not so specifically amended, voided or superseded shall remain in effect.

Clarification on Bidder Questions:

1. Q: Section 2: Ambient vaporizers calls for <u>three</u> parallel units with a minimum capacity of 4,500 scfh. Vaporizers are typically set up in pairs with a switching manifold. My recommendation would be to install 2 X 10,000 scfh vaporizers with a switching manifold. This will exceed your minimum flow requirements. Please let me know if this is an acceptable way to quote?

A: Both options are acceptable (3 x 4,500 scfh or 2 x 10,000 scfh).